

Optimizing Energy Efficiency for a High Rise Office Tower in Tropics

Driving Running Cost Down > 70% in a High-Rise

Presented by: Yong Kong, nyk@bezaire.com.my

Lead Author: CK Tang, ck@ckatwork.com



Organisers:



International Co-owners:



Sustainable Buildings
and Climate Initiative
Promoting Policies and Practices for Sustainability






Background

- 27 office levels
- 8 levels of podium
- Completion in Mid-2017
- Located in Johor Bharu, Malaysia. Just north of Singapore.
- Multi-tenanted office tower.
- Owners pay running cost for whole building Air-Conditioning and Common Area spaces.
- Building Energy Simulation Study Conducted to optimize building.

Study Concept

- Energy consumed by the Tower over 48 different simulation cases
- Analyze energy (BEI) and air conditioning Peak Cooling Load
- Each case brings improvement to passive and active systems



Computational Simulation Tool

- Integrated Environment Solutions Virtual Environment (IES VE) software
- Simulate sun position, cloud cover, shading, internal heat gain and M&E systems.
- Dynamic simulation model = Time varying model.



Organisers:



International Co-owners:



Simulation Cases and Results

Case	Descriptions	100% Occupancy					
		Total Energy per year (MWh)	BEI (kWh/m ²)	Total Energy Cost per year (RM)	Energy per year by Owner (MWh)	Energy Cost per year by Owner (RM)	Peak Cooling Load (kW)
1	Base Building	8,146.80	212.08	2,851,379	5,717.62	2,001,168	7,394.06
2	Daylight Implementation in Offices (3 meter Depth)	7,706.85	200.63	2,697,396	5,586.20	1,955,170	7,260.99
3	Daylight Implementation in Offices (4 meter Depth)	7,576.80	197.24	2,651,882	5,547.28	1,941,548	7,220.21
4	Daylight Implementation in Offices (5 meter Depth)	7,463.13	194.28	2,612,097	5,513.00	1,929,550	7,182.19
5	Roof Insulation (No insulation to 50mm insulation)	7,430.69	193.44	2,600,742	5,480.56	1,918,195	7,148.49
6	Roof Insulation (50mm insulation to 100mm insulation)	7,430.88	193.44	2,600,808	5,480.74	1,918,261	7,152.80
7	Wall insulation (No insulation to 25mm rockwool)	7,354.56	191.46	2,574,096	5,404.42	1,891,548	7,012.29
8	Glazing (All glass from conventional to Low-E)	6,858.71	178.55	2,400,550	4,908.58	1,718,002	6,239.73
9	Glazing (Light coloured glass to Double Glz Low-E)	6,765.74	176.13	2,368,010	4,815.61	1,685,462	6,141.19



Organisers:



International Co-owners:




Sustainable Buildings and Climate Initiative
Promoting Policies and Practices for Sustainability




Simulation Cases and Results

Building Energy Intensity (BEI) of each Case



Simulation Cases and Results

Peak Cooling Load of each Case



Analysis

Case 1: Base Building

Construction Material	
Typical Flat Roof – No insulation	U-value = 3.759
Standard Glazing	U-value = 4.825
Standard External Wall	U-value = 1.794
Lighting Power Density (MS 1525)	
Lobby / Walkway	20 W/m ²
Office	15 W/m ²
Observatory	15 W/m ²
Pantry	15 W/m ²
Staircase	15 W/m ²
Toilet	10 W/m ²
Common Area Night Light	
	50% switched on
Building Air Tightness	
Infiltration	0.5 ACH
Daylight Sensor	
	None
Light Shelves	
	None

Analysis

Case 1: Base Building cont.

Air Conditioning System	
Air side	Constant Air Volume (CAV)
Chiller	Constant speed
Chilled / Condenser Water Pump	Constant speed
Duct Static Pressure	1300 Pa
Fan Motor Efficiency	61.2%
Fresh Air CO2 sensor	None
Heat Recovery System	None
Chilled Water Delta T	12 F
Chilled Water Pump Pressure	40m
Chilled Water Pump Efficiency	63%
Chiller COP	5.5
Chilled Water Delta T	12 F
Chilled Water Pump Pressure	40m
Chilled Water Pump Efficiency	63%
Cooling Tower Efficiency	0.0463 kWe per HRT

Analysis

Case 1: Base Building

- BEI = 212.08 kWh/m²
- Peak Cooling Load = 7,394.06 kW



Organisers:



International Co-owners:



Analysis

Case 2, Case 3 and Case 4: Daylight Implementation

Design Improvement

- Daylight Sensor & light shelves at perimeter office areas up to 3m, 4m and 5m.

Results

- BEI = 194 kWh/m²
- Peak cooling load = 7,182 kW



Analysis

Case 5 and Case 6: Roof Insulation

Design Improvement

- Case 5: 50mm roof polystyrene insulation
- Case 6: 100mm roof polystyrene insulation

Results

- BEI = 193 kWh/m²
- Peak cooling load = 7,152 kW



Organisers:



International Co-owners:



Sustainable Buildings and Climate Initiative
Promoting Policies and Practices for Sustainability



Global Alliance
for Buildings and
Construction

Analysis


Case 7: Wall Insulation

Design Improvement

- 25mm rockwool insulation to external walls

Results

- BEI = 191 kWh/m²
- Peak cooling load = 7,012 kW



Analysis

Case 8, Case 9 and Case 10: Glazing

Design Improvement

- Case 8: All glazing single glazed, low-E. U-value = 3.806
- Case 9: Light green glazing double glazed low-E. U-value = 1.951.
- Case 10: All glazing double glazed, low-E. U-value = 1.951.

Results

- BEI = 172 kWh/m² (18.7% lower than base case)
- Peak cooling load = 5,923 kW (19.9% lower than base case)



Organisers:



International Co-owners:



Analysis


Case 11 and Case 12: Air Tightness

Design Improvement

- Case 11: Infiltration = 0.25 ACH
- Case 12: Infiltration = 0.10 ACH

Results

- BEI = 165 kWh/m²
- Peak cooling load = 5,583 kW



Analysis

Case 13 and Case 14: Office Lighting Power Density

Design Improvement

- Optimize lighting design layout for office areas
- Case 13: 9 W/m²
- Case 14: 7 W/m²

Results

- BEI = 154 kWh/m²
- Peak cooling load = 5,458 kW



Analysis

Case 15 and Case 16: Walkway / Lift Lobby Lighting Power Density

Design Improvement

- Optimize lighting design layout
- Case 13: 9 W/m²
- Case 14: 7 W/m²

Results

- BEI = 141 kWh/m²
- Peak cooling load = 5,267 kW



Organisers:



International Co-owners:



Sustainable Buildings and Climate Initiative
Promoting Policies and Practices for Sustainability



Global Alliance
For Buildings and
Construction

Analysis

Case 17: Walkway / Lift Lobby Night Light

Design Improvement

- Reduce night time light to 33%

Results

- BEI = 140 kWh/m²
- Peak cooling load = 5,248 kW



Organisers:



International Co-owners:



Sustainable Buildings and Climate Initiative
Promoting Policies and Practices for Sustainability



Global Alliance
for Buildings and
Construction

Analysis

Case 18: Toilet Lighting Power Density

Design Improvement

- Reduce toilet lighting power density to 7 W/m²

Results

- BEI = 140 kWh/m²
- Peak cooling load = 5,248 kW



Organisers:



International Co-owners:



Sustainable Buildings and Climate Initiative
Promoting Policies and Practices for Sustainability



Global Alliance
For Buildings and
Construction

Analysis

Case 19: Toilet Occupancy Sensor

Design Improvement

- Occupancy sensor to further reduce lighting to 3.5 W/m²

Results

- BEI = 140 kWh/m²
- Peak cooling load = 5,244 kW



Organisers:



International Co-owners:



Sustainable Buildings and Climate Initiative
Promoting Policies and Practices for Sustainability



Global Alliance
For Buildings and
Construction

Analysis

Case 20: Staircase Lighting Power Density

Design Improvement

- Reduce staircase lighting power density from 15 W/m² to 3 W/m²

Results

- BEI = 135 kWh/m²
- Peak cooling load = 5,168 kW



Organisers:



International Co-owners:



Sustainable Buildings and Climate Initiative
Promoting Policies and Practices for Sustainability



Global Alliance
For Buildings and
Construction

Analysis

Case 21: Air Conditioning Air Side

Design Improvement

- Implement Variable Air Volume (VAV) system
- Variable speed AHU, VAV boxes
- Supply air regulated to occupancy needs

Results

- BEI = 127 kWh/m²
- Peak cooling load = 5,178 kW



Organisers:



International Co-owners:



Sustainable Buildings and Climate Initiative
Promoting Policies and Practices for Sustainability



Global Alliance
for Buildings and
Construction

Analysis

Case 22 and Case 23: Duct Static Pressure

Design Improvement

- Optimize duct size, reduce tees, bends etc.
- Case 22: Total pressure = 900 Pa
- Case 23: Total pressure = 650 Pa

Results

- BEI = 120 kWh/m²
- Peak cooling load = 5,140 kW



Analysis


Case 24 and Case 25: AHU Air Filter

Design Improvement

- Improve air filter for all AHUs
- Case 24: High grade air filter, total pressure = 580 Pa
- Case 25: Electronic air filter, total pressure = 550 Pa

Results

- BEI = 114 kWh/m²
- Peak cooling load = 5,140 kW



Analysis

Case 26 and Case 27: Fan Efficiency

Design Improvement

- Improve all fan efficiency
- Case 26: air foil type fan, total efficiency = 70.2%
- Case 27: IE3 fan motor, total efficiency = 71.8%

Results

- BEI = 113 kWh/m²
- Peak cooling load = 5,127 kW



Organisers:



International Co-owners:



Sustainable Buildings and Climate Initiative
Promoting Policies and Practices for Sustainability



Global Alliance
for Buildings and
Construction

Analysis

Case 28: CO2 Sensor

Design Improvement

- Introduce CO2 sensors to regulate fresh air intake based on occupants need for fresh air
- CO2 sensor set to 900 ppm

Results

- BEI = 110 kWh/m²
- Peak cooling load = 4,973 kW



Organisers:



International Co-owners:



Sustainable Buildings and Climate Initiative
Promoting Policies and Practices for Sustainability



Global Alliance
For Buildings and
Construction

Analysis

Case 29: Heat Recovery System

Design Improvement

- Introduce heat recovery wheel to the fresh air intake

Results

- BEI = 108 kWh/m²
- Peak cooling load = 4,924 kW



Analysis

Case 30 and Case 31: Chilled Water Delta T

Design Improvement

- Increase chilled water delta T from 12 °F to 16 °F thus decreasing chilled water flow rate
- Case 30: Supply and return temperature = 42 °F and 58 °F
- Case 31: Supply and return temperature = 44 °F and 60 °F

Results

- BEI = 106 kWh/m²
- Peak cooling load = 4,880 kW. Peak cooling load does not show much decrease from here on. Active system improvement does not have much impact on cooling load.



Organisers:



International Co-owners:



Sustainable Buildings and Climate Initiative
Promoting Policies and Practices for Sustainability



Global Alliance
for Buildings and
Construction

Analysis

Case 32 and Case 33: Chilled Water Pump Pressure

Design Improvement

- Decrease pump pressure by optimizing pipe size, reduce bends, tees, etc.
- Case 32: Pump pressure = 30m
- Case 33: Pump pressure = 20m

Results

- BEI = 104 kWh/m²
- Peak cooling load = 4,869 kW.



Organisers:



International Co-owners:



Sustainable Buildings and Climate Initiative
Promoting Policies and Practices for Sustainability



Global Alliance
for Buildings and
Construction

Analysis

Case 34 and Case 35: Chilled Water Pump Efficiency

Design Improvement

- Improve pump efficiency
- Case 34: High efficiency pump, total efficiency 72%
- Case 33: IE3 motor, total efficiency = 74.4%

Results

- BEI = 104 kWh/m² (marginal)
- Peak cooling load = 4,868 kW.



Organisers:



International Co-owners:



Sustainable Buildings and Climate Initiative
Promoting Policies and Practices for Sustainability



Global Alliance
for Buildings and
Construction

Analysis

Case 36: Variable Primary Chilled Water Pump

Design Improvement

- Specify pump with VSD. Improves performance at part load

Results

- BEI = 102 kWh/m²
- Peak cooling load = 4,866 kW.



Organisers:



International Co-owners:



Sustainable Buildings
and Climate Initiative
Promoting Policies and Practices for Sustainability



Global Alliance
for Buildings and
Construction

Analysis

Case 37 and Case 38: Chiller Coefficient of Performance (COP)

Design Improvement

- Specify high efficiency chiller
- Case 37: COP = 6.2
- Case 38: COP = 6.6

Results

- BEI = 96 kWh/m²
- Peak cooling load = 4,807 kW.



Analysis

Case 39: Variable Speed Chiller

Design Improvement

- Specify chiller with VSD compressors. Gives better part load efficiency.

Results

- BEI = 91 kWh/m²
- Peak cooling load = 4,772 kW.



Organisers:



International Co-owners:



Sustainable Buildings and Climate Initiative
Promoting Policies and Practices for Sustainability



Global Alliance
For Buildings and
Construction

Analysis

Case 40: Condenser Water Delta T

Design Improvement

- Design a higher condenser water delta T of 12 °F hence decreasing flowrate

Results

- BEI = 89 kWh/m²
- Peak cooling load = 4,772 kW.



Organisers:



International Co-owners:



Sustainable Buildings and Climate Initiative
Promoting Policies and Practices for Sustainability



Global Alliance
for Buildings and
Construction

Analysis

Case 41 and Case 42: Condenser Pump Pressure

Design Improvement

- Decrease pump pressure by optimizing pipe size, deduce bends, tees, etc.
- Case 41: Pump pressure = 30m
- Case 42: Pump pressure = 20m

Results

- BEI = 85 kWh/m²
- Peak cooling load = 4,772 kW.



Organisers:



International Co-owners:



Sustainable Buildings and Climate Initiative
Promoting Policies and Practices for Sustainability



Global Alliance
for Buildings and
Construction

Analysis

Case 43 and Case 44: Condenser Pump Efficiency

Design Improvement

- Improve pump efficiency
- Case 43: High efficiency pump, total efficiency 72%
- Case 44: IE3 motor, total efficiency = 74.4%

Results

- BEI = 84 kWh/m²
- Peak cooling load = 4,772 kW.



Organisers:



International Co-owners:



Sustainable Buildings and Climate Initiative
Promoting Policies and Practices for Sustainability



Global Alliance
for Buildings and
Construction

Analysis

Case 45: Cooling Tower Efficiency

Design Improvement

- Select cooling tower with high efficiency. Efficiency decreased from 0.0463 kW/HRT to 0.0275 kW/HRT

Results

- BEI = 82 kWh/m²
- Peak cooling load = 4,772 kW.



Analysis

Case 46: Variable Speed Cooling Tower

Design Improvement

- Specifying a cooling tower with variable speed fan

Results

- BEI = 82 kWh/m²
- Peak cooling load = 4,772 kW.



Organisers:



International Co-owners:



Sustainable Buildings and Climate Initiative
Promoting Policies and Practices for Sustainability



Global Alliance
For Buildings and
Construction

Analysis

Case 47: Oversized Cooling Tower

Design Improvement

- Design return temperature from 29.4 °C to 28.5 °C/95 or 94 F

Results

- BEI = 82 kWh/m²
- Peak cooling load = 4,772 kW.



Organisers:



International Co-owners:



Sustainable Buildings and Climate Initiative
Promoting Policies and Practices for Sustainability



Global Alliance
For Buildings and
Construction

Analysis

Case 48: Faulty Daylight Sensors

Design Improvement

- This case does not improve on the design. Considers situation when daylight sensors are not functioning. Hence all office lights are switched on.

Results

- BEI = 89 kWh/m²
- Peak cooling load = 4,862 kW



Organisers:



International Co-owners:



Sustainable Buildings and Climate Initiative
Promoting Policies and Practices for Sustainability



Global Alliance
for Buildings and
Construction

Conclusion

- Each small improvement contribute to substantial overall savings.
 - Base building BEI = 212.08 kWh/m²
 - Final BEI (Case 47) = 82.25 kWh/m². A decrease of **61% (building overall)**
- Energy by owner.
 - Base building energy = 5,717 MWh (RM 2,001,168) per year.
 - Final energy (Case 47) = 1,510 MWh (RM 528,666) per year. A decrease of **73% (owner's running cost)**
- Peak air cond load.
 - Base building load = 7,394 kW
 - Final load (Case 48) = 4,862 kW. A decrease of **34% (capital cost reduction)**



Organisers:



International Co-owners:




Sustainable Buildings and Climate Initiative
Promoting Policies and Practices for Sustainability



Global Alliance
for Buildings and
Construction

Conclusion

Building Energy Intensity (BEI) of each Case



Organisers:



International Co-owners:




Sustainable Buildings and Climate Initiative
Promoting Policies and Practices for Sustainability



Global Alliance
for Buildings and
Construction

Conclusion

Peak Cooling Load of each Case



Organisers:



International Co-owners:



Sustainable Buildings and Climate Initiative
Promoting Policies and Practices for Sustainability



Global Alliance
for Buildings and
Construction

Summary

- Achieving very high energy efficiency requires the building to capitalize on every opportunity that increases efficiency on the building.
 - Each energy efficiency feature provides savings in the region of 1%~2% gains.
- Peak cooling load reduction is even smaller per feature, ranging from 0.5% ~ 1%.
 - But a combination of features will provide up to 34% peak cooling load reduction.



Organisers:



International Co-owners:



Thank you



Organisers:



International Co-owners:



Sustainable Buildings and Climate Initiative
Promoting Policies and Practices for Sustainability



Global Alliance
for Buildings and
Construction